Sliptest Australia Pty Ltd
NATA Accreditation No: 15374
11 Fuchsia Way Gaven QLD 4211, Gaven, QLD, 4211
kathryn@sliptest.com.au
www.sliptest.com.au
1300 754 783


Stoneworld - Aggregate Range Matt SmoothGrip 600x600mm Tiles - Various Colours - Wet Sliptest AN150323-1

15 Mar 2023

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	15 Mar 2023
Test Report Number:	AN150323-1
Client Name & Billing Address:	Stoneworld Qld - 1/20-24 Riverland Drive LOGANHOLME
Surface Tested : (Samples and Test Information Supplied by Client)	Aggregate Range Matt SmoothGrip - AGG DGY, LGY, WHT 60MS GN - 2245A5
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Testing Officer / Approved Signatory:	Alyssa Neill
Pendulum in use - Calibration Date :	#2047 - Munro-Stanley Portable Skid Tester (C : 25.08.2022)
Signature of Approved Signatory :	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
AGG DGY	65	65	65	65	65	65	N/A	
AGG DGY	70	70	69	68	68	68	N/A	
AGG LGY	70	70	70	70	69	70	N/A	
AGG LGY	74	74	74	72	72	73	N/A	
AGG WHT	68	68	67	67	67	67	N/A	

Reported SRV For Test Area :	69
CLASSIFICATION using Slider 96 (4S Slider)	P5 = > 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

stoneworld
NATIONWIDE TILES & SURFACES

1st August 2023

TO WHOM IT MAY CONCERN

Re : SLIP RESISTANCE CLASSIFICATION REPORT – Aggregate Matt SmoothGrip

Dear Sir / Madam,

Please find attached the Slip Resistance Classification Report for the Stoneworld tile, Aggregate Matt SmoothGrip.

Please be aware that the attached test results are from the batch of tiles that were available at the time of testing. These test results are provided as an indication of slip rating as the slip rating may vary for each batch of tiles. Stoneworld provides slip rating test results as a guide ONLY and takes no responsibility for the slip rating of any non-tested batches, nor is it liable for any costs incurred in any further testing or re-testing of tiles.

The test result of tiles may change subsequent to delivery, through the laying process, during the completion of the building work, or through wear and tear.

Regards,

Alan Williams

GROUP NATIONAL MANAGER

10 YEAR WARRANTY