Sliptest Australia Pty Ltd
NATA Accreditation No: 15374
11 Fuchsia Way Gaven QLD 4211, Gaven, QLD, 4211
kathryn@sliptest.com.au
www.sliptest.com.au
1300 754 783

NATA Accreditation No.15374 for Compliance with ISO 17025 – Testing

Stoneworld - Eliza Series External (Complete Range) - Wet Sliptest MO101024-11 — 10 Oct 2024

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013

This Test Report Is In Accordance with Appendix A	Wet Pendulum Test
Date Tested:	10 Oct 2024
Test Report Number:	MO101024-11
Client Name & Billing Address:	Stoneworld Qld - 1/20-24 Riverland Drive LOGANHOLME
Surface Tested :	Eliza Series External (Complete Range) - Fine Texture
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Any Variations to Standards	N/A
Testing Officer / Approved Signatory:	Mitchell Ording
Pendulum in use - Calibration Date :	#1109 - Munro-Stanley Portable Skid Tester (C: 27.04.23 - BS 7976-3:2002+A1:2013)
Signature of Approved Signatory :	

Test Results : (Samples and Test Information Supplied by Client)

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN	SCV :	Surface Picture
Grey	70	70	70	70	70	70	N/A	
Beige	65	65	63	63	62	63	N/A	
Beige	60	60	60	59	57	59	N/A	
White	65	65	64	64	64	64	N/A	
White	66	66	65	65	64	65	N/A	

Reported SRV For Test Area :	64
CLASSIFICATION using Slider 96 (4S Slider)	P5 = > 54

Declaration: The factual matters stated within this report are, to the best of my knowledge, true and correct. I have completed all enquiries that I consider appropriate in formulating my conclusions. The opinions stated by me within this report are genuinely held by me. The report contains reference to all matter which I regard as significant. I understand that my overriding duty as an expert is to assist the Court and have complied with this duty. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Any enquiries in relation to this report should be directed to Sliptest Australia Pty. Ltd.quoting the applicable test report number. Accredited for Compliance with ISO/IEC 17025. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials & AS 4663:2013 Classification of existing pedestrian surface materials - Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014. This report and covering documentation was prepared by SliptestAustralia Pty. Ltd. on behalf of our client as named in the report. Neither Sliptest Australia Pty. Ltd. nor any person acting on our behalf (a) makes any warranty, express or implied, with respect to the use of any information or methods disclosed in this report or (b) assumes any liability with respect to the use of any information or methods disclosed in this report or covering information. Any recipient of this document, by their acceptance or use of this document, releases Sliptest Australia Pty. Ltd. and their affiliates from any liability for direct, indirect, consequential or special loss or

Submitted by: Mitchell Ording @ 10:24:16 10 Oct 2024
Submission ID: 18600768
Environment friendly, paperless solution by www.formitize.com

Issue: Controlled Document ID: 23422 - 1 PAGE TEST FORM (AS4586 ONLY - Wet or Dry Pendulum Testing) Version: 182

damage whether arising in contract, warranty, express or implied, tort or otherwise, and irrespective of fault, negligence and strict liability.

Submitted by: Mitchell Ording @ 10:24:16 10 Oct 2024
Submission ID: 18600768
Environment friendly, paperless solution by www.formitize.com

Issue: Controlled Document ID: 23422 - 1 PAGE TEST FORM (AS4586 ONLY - Wet or Dry Pendulum Testing) Version: 182

stoneworld
NATIONWIDE TILES & SURFACES

1st November 2024

TO WHOM IT MAY CONCERN

Re : SLIP RESISTANCE CLASSIFICATION REPORT – Eliza Structured

Dear Sir / Madam,

Please find attached the Slip Resistance Classification Report for the Stoneworld tile, Eliza Structured.

Please be aware that the attached test results are from the batch of tiles that were available at the time of testing. These test results are provided as an indication of slip rating as the slip rating may vary for each batch of tiles. Stoneworld provides slip rating test results as a guide ONLY and takes no responsibility for the slip rating of any non-tested batches, nor is it liable for any costs incurred in any further testing or re-testing of tiles.

The test result of tiles may change subsequent to delivery, through the laying process, during the completion of the building work, or through wear and tear.

Regards,

Alan Williams

GROUP NATIONAL MANAGER

10 YEAR WARRANTY

PO BOX 307 TOONGABBIE NSW 2146

www. stoneworld.com.au

NSW | ABN: 26 003 307 015
1/28 Oramzi Road
Girraween NSW 2145
Ph +61 2 9688 9999 | Fax +61 2 9688 9988
info@stoneworld.com.au

QLD | ABN: 12 069 824 282
1/20-24 Riverland Drive
Loganholme QLD 4129
Ph +61 7 3827 5555 | Fax +61 7 3827 5566
stoqld@stoneworld.com.au

VIC | ABN: 50 105 594 894
1/25 Heales Road
Corio VIC 3214
Ph +61 3 5272 3300 | Fax +61 3 5272 1144
salesvic@stoneworld.com.au

WA | ABN: 88 151 980 013
1/45 Edward Street
Osborne Park WA 6107
Ph +61 8 9451 5099 | Fax +61 8 9451 5199
stowa@stoneworld.com.au