Slip Test Report

Sample Number	2409281801	**Test Sheet Number**	YMT12545A-240928	**Date of Test**	30/09/2024
Tile Name	Montauk Grey P4 (Size: 450x450x7.5mm)	**Tile Code**	YMT12545A	**Report Number**	R240268
Tile Manufacturer	National Ceramic Industries Australia (NCIA) www.ncia.com.au		**ABN**	83 100 467 267	
Address	175 Racecourse Rd, Rutherford, NSW 2320		**Phone**	02 4931 8400	

Testing performed in Accordance with AS4586-2013 Amd 1:2017, Appendix A Wet Pendulum Test Method with a 96 Rubber slider, conditioned with P400C paper dry, followed by 3 µm wet lapping film

Temperature (Laboratory):	23.8°C	**Testing Instrument:**	Pendulum Friction Tester (Munro Stanley Portable Skid Resistance Tester S/N: 2081) Calibration Date: 24 June 2024

Test Specimen (Unfixed)	**Slope of Surface**	**Cleaning Pre-testing**	**Pendulum Swing Results (BPN)**					**Mean (BPN)** (last 3 swings)	**Classification According to AS4586-2013**	
			1	**2**	**3**	**4**	**5**			
Tile 1	Flat and level surface	Water & Scrubbing	48	48	48	48	48	48	**P4**	
Tile 2	Same as above	Water & Scrubbing	46	46	46	46	46	46		
Tile 3	Same as above	Water & Scrubbing	45	45	45	45	45	45		
Tile 4	Same as above	Water & Scrubbing	44	44	45	45	45	45	**Reported Slip Resistance Value of Sample (BPN)**	46
Tile 5	Same as above	Water & Scrubbing	45	45	45	45	45	45		

Slope Correction Value (SCV) = No
Results relate only to the items tested

Test Location:	NCIA Tile Testing Laboratory, 175 Racecourse Rd, Rutherford, NSW, 2320 Australia		
Report Issued by:	NCIA Pendulum Friction Tester Laboratory	**Issue Date:**	01/10/2024
Test Officer	Hong Lu	**Authorised by:**	Hong Lu

stoneworld
NATIONWIDE TILES & SURFACES

1st November 2024

TO WHOM IT MAY CONCERN

Re : SLIP RESISTANCE CLASSIFICATION REPORT – Montauk Structured

Dear Sir / Madam,

Please find attached the Slip Resistance Classification Report for the Stoneworld tile, Montauk Structured.

Please be aware that the attached test results are from the batch of tiles that were available at the time of testing. These test results are provided as an indication of slip rating as the slip rating may vary for each batch of tiles. Stoneworld provides slip rating test results as a guide ONLY and takes no responsibility for the slip rating of any non-tested batches, nor is it liable for any costs incurred in any further testing or re-testing of tiles.

The test result of tiles may change subsequent to delivery, through the laying process, during the completion of the building work, or through wear and tear.

Regards,

Alan Williams

GROUP NATIONAL MANAGER

10 YEAR WARRANTY